

INDIAN RIVER SHORES BUILDING DEPARTMENT

FLORIDA ENERGY CONSERVATION CODE

Mandatory Duct Inspection Certification for HVAC change-out

For use when part of the duct and/or entire HVAC system has been replaced (Section 101.4.7.1.1 & FS 553.912)

Owner: _____	Contractor name: _____
Street address: _____	Jurisdiction: Indian River Shores
City: _____	Permit No.: _____
Zip: _____	Final insp. date: _____

I certify that I have inspected the duct work associated with the HVAC unit referenced by the permit listed above and found it complies with the requirements of Section 101.4.7.1.1 as indicated below:

- Where needed, the existing ducts have been sealed using reinforced mastic or code-approved equivalent.
- Ducts are located within conditioned space. (Section 101.4.7.1.1 exception 1)
- The joints or seams are already sealed with fabric and mastic (Section 101.4.7.1.1 exception 2)
- System was tested (see below) and repairs were made as necessary (Section 101.4.7.1.1 exception 3)

Signature: _____ Date: _____

Printed Name: _____

Owner Contractor A/C Contractor - License #: _____

I certified I have tested the replaced air distribution system(s) referenced by the permit listed above at a pressure differential of 25 Pascals (0.10 in. w.c.).

Signature: _____ Date: _____

Printed Name: _____